



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

WIARTON
DRINKING WATER SYSTEM

Large Municipal Residential

SCHEDULE 22
SUMMARY REPORT

For the period of
JANUARY 1, 2019 TO DECEMBER 31, 2019

Summary

This report is a summary of water quality and quantity information submitted in accordance with Schedule 22 of Ontario's Drinking Water System Regulation for the reporting period of January 1, 2019 to December 31, 2019 for the Wiarton Drinking Water System located in the Town of South Bruce Peninsula. The summary includes the following information:

- Any requirements of the Act and Regulation, Orders or System Approval(s) that the system failed to meet during the reporting period and the measures taken to correct each failure.
- A summary of the quantities and flow rates of water supplied during the reporting period, including monthly averages and maximum daily flows.
- A comparison of the average and monthly maximum daily flows to the approved capacity specified in the System Approval.

Issues of Non-Compliance

An MECP Drinking Water System Inspection was performed on January 31, 2020. On March 3, 2020 the report for this inspection was issued, the Wiarton Drinking Water System received an inspection rating of 100%

The following is a summary of the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water license, and any orders applicable to the system that were not met at any time during the period covered by the report; as well as the duration of the failure and the measures that were taken to correct the failure:

* There were no non-compliances during the reporting period.

Refer to the Section 11 Annual Report for a summary of any Adverse Water Quality Incident(s) which occurred during the reporting period.

Assessment of Flowrates and Quantity of Water Supplied

The following tables summarize the quantities (Table 1) and flow rates (Table 2) of the water supplied during the period covered by the report, including monthly average and maximum daily flows as well as a comparison of the summary to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water license.

As per Municipal Drinking Water License (MDWL) 094-102 (Issue Number: 3, expires March 17, 2020), the maximum daily volume of treated water that flows from the treatment subsystem to the distribution system shall not exceed a rated capacity of 5,400 m³/day. There is no maximum allowable limit listed in the MDWL for the flowrate of water that flows into a treatment subsystem, however, raw water flowrate has been included in this report (Table 3).

Table 1. Treated Water Monthly Average and Maximum Daily Flows and Comparison to Rated Capacity for 2019

2019	Treated Water Flow			
	Average Flow (m ³ /day)	Percent of Rated Capacity (%)	Maximum Flow (m ³ /day)	Percent of Rated Capacity (%)
January	1134.09	21.0	1452.85	26.9
February	1255.66	23.3	1494.83	27.7
March	1211.51	22.4	1500.73	27.8
April	1187.58	22.0	1532.66	28.4
May	1216.50	22.5	1554.82	28.8
June	1322.37	24.5	1708.07	31.6
July	1245.15	23.1	1613.52	29.9
August	1185.65	22.0	1502.46	27.8
September	1058.19	19.6	1431.28	26.5
October	1058.86	19.6	1411.86	26.1
November	1042.49	19.3	1394.93	25.8
December	1096.70	20.3	1472.50	27.3

Table 2. Treated Water Monthly Average and Maximum Flowrates for 2019

2019	Treated Water	
	Average Flowrate (l/s)	Maximum Flowrate (l/s)
January	66.01	76.56
February	66.19	75.13
March	66.11	76.11
April	66.31	76.96
May	66.31	75.38
June	66.57	77.62
July	66.67	78.16
August	67.39	76.93
September	66.61	76.07
October	66.56	76.32
November	66.56	76.25
December	66.48	76.02

Table 3. Raw Water Monthly Average and Maximum Flowrates for 2019

2019	Raw Water	
	Average Flowrate (l/s)	Maximum Flowrate (l/s)
January	49.12	65.55
February	49.18	55.92
March	49.25	55.64
April	49.33	56.50
May	49.25	56.86
June	49.29	57.53
July	49.23	57.27
August	48.65	56.93
September	48.26	56.07
October	48.06	56.04
November	48.15	56.24
December	48.21	55.97



Ontario Clean Water Agency
Agence Ontarienne Des Eaux

WIARTON
DRINKING WATER SYSTEM

Large Municipal Residential

SECTION 11
ANNUAL REPORT

For the period of
JANUARY 1, 2019 TO DECEMBER 31, 2019

Prepared by the Ontario Clean Water Agency
For The Town of South Bruce Peninsula

Drinking Water System Number:	220002681
Drinking Water System Name:	Warton Drinking Water System
Drinking Water System Owner:	Town of South Bruce Peninsula
Drinking Water System Category:	Large Municipal Residential
Reporting Period:	January 1, 2019 to December 31, 2019

Does the Drinking Water System serve more than 10,000 people?

No.

Is your annual report available to the public at no charge on a web site on the Internet?

Yes.

Location where the Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection:

Town of South Bruce Peninsula
315 George Street
Warton, Ontario
N0H 2T0

Drinking-Water Systems (if any), which receive all of their drinking water from your system:

- Oxenden Distribution System (260004215)
- Oliphant Drinking Water System (220007695)

Did you provide a copy of the annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes

How system users are notified that the annual report is available, and is free of charge:

- | | |
|-------------------------------------|--|
| <input checked="" type="checkbox"/> | Public access/notice via the web |
| <input checked="" type="checkbox"/> | Public access/notice via Government Office |
| <input type="checkbox"/> | Public access/notice via a newspaper |
| <input type="checkbox"/> | Public access/notice via Public Request |
| <input type="checkbox"/> | Public access/notice via a Public Library |
| <input type="checkbox"/> | Public access/notice via other method: _____ |

Description of Drinking Water System:

The Warton Drinking Water System (DWS) is a Class III Treatment and Class II Distribution System.

The Warton Water Treatment Plant is supplied by Colpoy's Bay (Georgian Bay). The treatment system consists of the following:

- A bar screen and standby travelling screen (low lift station section)
- Sodium hypochlorite (pre-chlorination for zebra mussel control and chlorination after filtration)
- Coagulation and Flocculation
- Filtration (dual media gravity filters)
- Waste Residual Management (filter backwash wastewater sedimentation tank with sludge withdrawal. Sludge is discharged to the sanitary sewer and the supernatant is dechlorinated and then discharged to Colpoy's Bay)
- Polymer system (for enhancing settling in the wastewater sedimentation tank)
- Sodium Bisulphate feed system (prior to flocculation or to raw water well for dechlorination/pH)

correction and to the wastewater residual management system for dechlorination)

- UV Disinfection System
- Activated carbon feed system for taste and odour control (currently is not being used)
- Clearwell (for storage and to achieve required contact time)
- SCADA System (for monitoring and control)
- Diesel generator set (for emergency back-up power)

The distribution system consist of the following:

- Wiarton Standpipe and Booster Station.
- Approximately 23.5 kilometers of distribution water mains

List of water treatment chemicals used during the reporting period:

- Sodium Hypochlorite 12%
- PAX-XL1900 Coagulation
- LIPQIPAM A-307PG Flocculation
- Sodium Metabisulfite

Significant expenses were incurred to:

- | | |
|-------------------------------------|---------------------------------------|
| <input checked="" type="checkbox"/> | Install required equipment |
| <input checked="" type="checkbox"/> | Repair required equipment |
| <input checked="" type="checkbox"/> | Replace required equipment |
| <input type="checkbox"/> | No significant expenses were incurred |

Description of expenses:

- Replaced alum pumps & programmed interlock in PLC
- Installed filter #1 low level float
- Replaced power supply on filter #1 PLC
- Installed logic to run plant in pressure mode
- Installed replacement parts for filter #1 low level sensor
- Repaired water service line break
- Replaced UV lamps
- Repaired watermain valve
- Flushed, swabbed, pressurized, sampled new 12" watermain
- Replaced copper line to flowmeter
- Replaced chlorine pump #3 head
- Replaced PRV on chlorine pumps 3 & 4
- Replaced low lift pump #4 cooling line valve
- Replaced cooling line valve on high lift pump #1
- Installed new pressure tank at booster station
- Replaced tracer wire
- Replaced water meters
- Installed curb stop locks
- Replaced power back up units
- Installed replacement block heater on WTP diesel generator.
- Replaced electric heaters in diesel generator room and chemical room
- Installed new float level indicator on Booster Station Diesel Tank
- Rebuilt instrumentation water feed pump
- Replaced WTP clear well level transmitter

- Replaced pressure tank at Booster Station

Details on the notices submitted in accordance with subsection 18 (1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre:

Date of Incident	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
n/a	n/a	n/a	n/a	n/a	n/a

Table 1. Microbiological testing done under Schedule 10, 11 or 12 of Regulation 170/03 during this reporting Period

Location	Number of Samples	Range of E.coli Results		Range of Total Coliforms Results		Number of HPC Samples	Range of HPC Samples	
		Minimum	Maximum	Minimum	Maximum		Minimum	Maximum
Raw (RW)	52	0	20	0	78	n/a	n/a	n/a
Treated (TW)	52	0	0	0	0	52	0	2
Distribution (DW)	160	0	0	0	0	52	0	3

Table 2. Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results	
		Minimum	Maximum
Turbidity, On-Line (NTU) - Filt1	8760	0.02	0.56
Turbidity, On-Line (NTU) - Filt2	8760	0.03	1.05*
Free Chlorine Residual, On-Line (mg/L) - TW	8760	0.62	1.98
Free Chlorine Residual, In-House (mg/L) - DW	730	0.44	1.41

*April 9th, 2019 turbidity was > 1 NTU for less than 1 minute. Not reportable, monthly filter efficiency was achieved.

Table 3. Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of Order of MDWL	Parameter	Date Sampled	Result	MDWL Allowable Annual Average Concentration
January 12, 2018 094-102 (Issue 3)	Total Suspended Solids (Filter backwash - composite)	2019 (Quarterly)	10.5 mg/L	25 mg/L

NOTE: Quarterly samples are required as per MDWL 094-102, Issue3.

Table 4. Summary of Inorganic parameters tested during this reporting period or most recent sample results

	Sample Date (yyyy/mm/dd)	Sample Result	Exceedance
Antimony: Sb (µg/L) - TW	2019/01/08	0.15	No
Arsenic: As (µg/L) - TW	2019/01/08	0.3	No
Barium: Ba (µg/L) - TW	2019/01/08	15.1	No
Boron: B (µg/L) - TW	2019/01/08	14.0	No
Cadmium: Cd (µg/L) - TW	2019/01/08	<MDL 0.003	No
Chromium: Cr (µg/L) - TW	2019/01/08	0.21	No
Mercury: Hg (µg/L) - TW	2019/01/08	0.03	No
Selenium: Se (µg/L) - TW	2019/01/08	0.11	No
Uranium: U (µg/L) - TW	2019/01/08	0.057	No
Fluoride (mg/L) - TW	2018/01/08	0.07	No
Nitrite (mg/L) - TW	2019/01/08	<MDL 0.003	No
Nitrite (mg/L) - TW	2019/04/01	<MDL 0.003	No
Nitrite (mg/L) - TW	2019/07/08	<MDL 0.003	No
Nitrite (mg/L) - TW	2019/10/07	<MDL 0.003	No
Nitrate (mg/L) - TW	2019/01/08	0.264	No
Nitrate (mg/L) - TW	2019/04/01	0.255	No
Nitrate (mg/L) - TW	2019/07/08	0.239	No
Nitrate (mg/L) - TW	2019/10/07	0.236	No
Sodium: Na (mg/L) - TW	2018/01/08	7.41	No

NOTE: There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

NOTE: Fluoride and Sodium are to be sampled every 60 months. The most recent samples for Sodium were taken on January 8, 2018. The next set of Sodium samples are to be taken in January 2023. The most recent samples for Fluoride were taken on January 8, 2018. The next set of Fluoride samples are to be taken in January 2023.

Table 5. Summary of lead testing under Schedule 15.1 during this reporting period.

Location Type	Number of Samples	Range of Lead Results		Number of Exceedances
		Minimum	Maximum	
Plumbing	n/a	n/a	n/a	n/a
Distribution (µg/L)	0	-	-	0

NOTE: This system now qualifies for the plumbing exemption as per Ontario Regulation 170/03 Schedule 15.1-5 (9) (10). Four (4) distribution lead samples are only taken every 36 months (i.e. 2 samples per period). The most recent set of samples was taken in 2018. The next set of lead samples will be taken in 2021.

Table 6. Summary of Organic parameters sampled during this reporting period or most recent sample results.

	Sample Date (yyyy/mm/dd)	Sample Result	Exceedance
Alachlor (µg/L) - TW	2019/01/08	<MDL 0.02	No
Atrazine + N-dealkylated metabolites (µg/L) - TW	2019/01/08	<MDL 0.01	No
Azinphos-methyl (µg/L) - TW	2019/01/08	<MDL 0.05	No
Benzene (µg/L) - TW	2019/01/08	<MDL 0.32	No
Benzo(a)pyrene (µg/L) - TW	2019/01/08	<MDL 0.004	No
Bromoxynil (µg/L) - TW	2019/01/08	<MDL 0.33	No
Carbaryl (µg/L) - TW	2019/01/08	<MDL 0.05	No
Carbofuran (µg/L) - TW	2019/01/08	<MDL 0.01	No
Carbon Tetrachloride (µg/L) - TW	2019/01/08	<MDL 0.16	No
Chlorpyrifos (µg/L) - TW	2019/01/08	<MDL 0.02	No
Diazinon (µg/L) - TW	2019/01/08	<MDL 0.02	No
Dicamba (µg/L) - TW	2019/01/08	<MDL 0.2	No
1,2-Dichlorobenzene (µg/L) - TW	2019/01/08	<MDL 0.41	No
1,4-Dichlorobenzene (µg/L) - TW	2019/01/08	<MDL 0.36	No
1,2-Dichloroethane (µg/L) - TW	2019/01/08	<MDL 0.35	No
1,1-Dichloroethylene (µg/L) - TW	2019/01/08	<MDL 0.33	No
Dichloromethane (Methylene Chloride) (µg/L) - TW	2019/01/08	<MDL 0.35	No
2,4-Dichlorophenol (µg/L) - TW	2019/01/08	<MDL 0.15	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW	2019/01/08	<MDL 0.19	No
Diclofop-methyl (µg/L) - TW	2019/01/08	<MDL 0.4	No
Dimethoate (µg/L) - TW	2019/01/08	<MDL 0.03	No
Diquat (µg/L) - TW	2019/01/08	<MDL 1.0	No
Diuron (µg/L) - TW	2019/01/08	<MDL 0.03	No
Glyphosate (µg/L) - TW	2019/01/08	<MDL 1.0	No
Malathion (µg/L) - TW	2019/01/08	<MDL 0.02	No
Metolachlor (µg/L) - TW	2019/01/08	<MDL 0.01	No
Metribuzin (µg/L) - TW	2019/01/08	<MDL 0.02	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW	2019/01/08	<MDL 0.3	No
Paraquat (µg/L) - TW	2019/01/08	<MDL 1.0	No
PCB (µg/L) - TW	2019/01/08	<MDL 0.04	No
Pentachlorophenol (µg/L) - TW	2019/01/08	<MDL 0.15	No
Phorate (µg/L) - TW	2019/01/08	<MDL 0.01	No
Picloram (µg/L) - TW	2019/01/08	<MDL 1.0	No
Prometryne (µg/L) - TW	2019/01/08	<MDL 0.03	No
Simazine (µg/L) - TW	2019/01/08	<MDL 0.01	No
Terbufos (µg/L) - TW	2019/01/08	<MDL 0.01	No
Tetrachloroethylene (µg/L) - TW	2019/01/08	<MDL 0.35	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW	2019/01/08	<MDL 0.2	No
Triallate (µg/L) - TW	2019/01/08	<MDL 0.01	No
Trichloroethylene (µg/L) - TW	2019/01/08	<MDL 0.44	No
2,4,6-Trichlorophenol (µg/L) - TW	2019/01/08	<MDL 0.25	No
Trifluralin (µg/L) - TW	2019/01/08	<MDL 0.02	No
Vinyl Chloride (µg/L) - TW	2019/01/08	<MDL 0.17	No
Trihalomethane: Total (µg/L) Annual Average - DW	2019 (Quarterly)	33.2	No
HAA Total (ug/L) Annual Average - DW	2019 (Quarterly)	13.24	No

Table 7. List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
n/a	n/a	n/a	n/a

NOTE: This is required only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, small municipal non-residential, large non municipal non-residential)