

Addendum 1



Town of
**SOUTH BRUCE
PENINSULA**

The Corporation of the Town of South Bruce Peninsula

Quotation PW 17-13

Reconstruction of Allenford Road

Addendum 1

July 24, 2017

This addendum forms part of the bid document for Quotation PW 17-13 for the above noted project, and shall be read in conjunction with the bid document, posted July 14, 2017. The following revisions supersede the information contained in the bid document issued for the above-noted project to the extent referenced and shall become part thereof.

1. Page 10 of 24 – Specifications

The tender document states that “the successful bidder shall install sub-drain on both sides of Allenford Road. The sub-drain will run on the east side of Allenford Road from Alice Street north for approximately 85 metres and on the west side of Allenford Road from Alice Street north for approximately 235 metres” but the tender document did not specify the size of the sub-drain.

Town Response: The successful bidder shall install 150 mm diameter sub-drain installed along Allenford Road.

** Please Note: This addendum notice must appear with your tender submission.

Andrew Sprunt
Manager of Public Works

Signature of Bidder

Name of Bidder (Please Print)

Company Name

Date