



Clarification to Tender Addendum No. 3

This Clarification to Addendum consists of 1 page.

Date	March 26, 2020	Project No.	300050111.1200
Project	Berford Street Reconstruction and Streetscaping Improvement		
To	All Tenderers		

Please confirm that you have received this Addendum by Email to Sharon.Jungkind@rjburnside.com and Paul.Hausler@rjburnside.com

Please be advised of the following changes/additions to the Bid Documents and complete the addendum table on the first page of the Bid Form (Document B).

1. Clarification

As per Special Provision H9 – Traffic Signal Poles (Black), Base Mounted the Valmont 8524 poles are specified.

The 8524 (7.3 m) is light duty and cannot carry longer than a maximum of a 15' (4.6 m) traffic arm. There are instances where both a 20' (6.1 m) and a 22' (6.7 m) traffic arm is required. In these cases, the Valmont 8624 heavy duty pole will be required. All the other traffic arms are 3.7 m or less, so the Valmont 8524 is sufficient.

In the SP the pole is referred to as a "Round" steel pole this is incorrect, the 8524/8624 is a standard "tapered octagonal" pole.

End of Clarification to Addendum No. 3