



**Ontario Clean Water Agency  
Agence Ontarienne Des Eaux**

**AMABEL-SAUBLE  
WATER TREATMENT PLANT**

**Large Municipal Residential Drinking Water System**

**SCHEDULE 22  
SUMMARY REPORT**

**For the period of  
JANUARY 1, 2014 TO DECEMBER 31, 2014**

**Prepared by the Ontario Clean Water Agency  
For The Corporation of the Town of South Bruce Peninsula**

**SUMMARY**

This report is a summary of water quality and quantity information submitted in accordance with Schedule 22 of Ontario's Drinking Water System Regulation for the reporting period of January 1, 2014 to December 31, 2014 for the Amabel-Sauble Water Treatment Plant located in the Town of South Bruce Peninsula.

The summary includes:

1. Any requirements of the Act and Regulation, Orders or System Approval (s) that the system failed to meet during the reporting period and the measures taken to correct each failure.
2. A summary of the quantities and flow rates of water supplied during the reporting period, including monthly averages and maximum daily flows.
3. A comparison of the average and monthly maximum daily flows to the approved capacity specified in the System Approval.

**ISSUES OF NON-COMPLIANCE**

The following table lists the requirements of the Act, Regulations, System Approval(s) and any Order that the system failed to meet during the reporting period and the measures taken to correct each failure:

MOE Compliance Inspection commencing May 16, 2014, which was routine and announced resulted in an Inspection Report Rating of 100.0 %.

No Actions Required.

**ASSESSMENT OF FLOW RATES AND QUANTITIES OF WATER SUPPLIED**

The following table lists the quantities and flow rates of the water supplied during the reporting period covered by this report, including monthly average and maximum daily flows and a comparison to the rated capacity and flow rates specified in the system approval:

Amabel-Sauble Water Treatment Plant

| Month     | Average Day Flow | % of Rated Capacity<br>687 m3/d | Maximum Day Flow | % of Rated Capacity<br>687 m3/d |
|-----------|------------------|---------------------------------|------------------|---------------------------------|
| January   | 78.71            | 11.46                           | 244.55           | 35.60                           |
| February  | 114.44           | 16.66                           | 259.33           | 37.75                           |
| March     | 84.31            | 12.27                           | 141.24           | 20.56                           |
| April     | 107.64           | 15.67                           | 259.68           | 37.80                           |
| May       | 115.13           | 16.76                           | 149.18           | 21.71                           |
| June      | 160.26           | 23.33                           | 289.56           | 42.15                           |
| July      | 157.91           | 22.99                           | 320.49           | 46.65                           |
| August    | 147.13           | 21.42                           | 259.28           | 37.74                           |
| September | 109.59           | 15.95                           | 185.76           | 27.04                           |
| October   | 120.34           | 17.52                           | 410.67           | 59.78                           |
| November  | 97.78            | 14.23                           | 137.76           | 20.05                           |
| December  | 97.96            | 14.26                           | 137.64           | 20.03                           |

# O.Reg 170 SECTION 11 ANNUAL REPORT

|  |                                      |
|--|--------------------------------------|
| <b>Drinking-Water System Number:</b>   | 220007917                            |
| <b>Drinking-Water System Name:</b>     | Amabel-Sauble Well Supply            |
| <b>Drinking-Water System Owner:</b>    | Town of South Bruce Peninsula        |
| <b>Drinking-Water System Category:</b> | Large Municipal Residential          |
| <b>Period being reported:</b>          | January 1, 2014 to December 31, 2014 |

|  |   |
|--|---|
| <p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p><b>Does your Drinking-Water System serve more than 10,000 people? Yes [ ] No [X]</b></p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet? Yes [X] No [ ]</b></p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b></p> <div style="border: 1px solid black; padding: 5px; margin-top: 5px;">             Town of South Bruce Peninsula<br/>             315 George Street<br/>             Wiarton, Ontario<br/>             N0H 2T0<br/>             519-534-1400         </div> | <p style="text-align: center;"><b><u>Complete for all other Categories.</u></b></p> <p><b>Number of Designated Facilities served:</b><br/> <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div> </p> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ ]</b></p> <p><b>Number of Interested Authorities you report to:</b><br/> <div style="border: 1px solid black; width: 100px; height: 20px; margin: 5px 0;"></div> </p> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ ]</b></p> |
|--|---|

**List Drinking-Water Systems, which receive all of their drinking water from your system:**

N/A

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**

Yes [ ] No [ ] N/A [X]

**Indicate how you notified system users that your annual report is available, and is free of charge.**

- [X] Public access/notice via the web
- [X] Public access/notice via Government Office
- [ ] Public access/notice via a newspaper
- [ ] Public access/notice via Public Request
- [ ] Public access/notice via a Public Library
- [ ] Public access/notice via other method \_\_\_\_\_

# O.Reg 170 SECTION 11 ANNUAL REPORT

## Describe your Drinking-Water System

Class II Water Treatment  
Class II Water Distribution

The Amabel-Sauble Well Supply Drinking-Water System has a 150 mm diameter, 102 meter deep drilled well equipped with a submersible pump rated at 4 L/s, a second 150 mm diameter 86.9 meter deep drilled well with a submersible pump rated at 4 L/s, and a third 150 mm diameter, 87 meter deep drilled well which is and is equipped with a 6.05 L/s capacity 10 HP submersible pump and is used only as a standby source. The Amabel-Sauble Water Treatment Plant houses the treatment and control facilities including:

- Iron Removal with two pressure vessels containing anthracite and catalytic media.
- Chlorine Disinfection System with three pumps each with a dedicated duty. One pump is used for iron and manganese oxidation, one is used to chlorinate treated water after UV disinfection prior to water entering the clearwell and the third pump is used for post chlorination.
- Additional Disinfection System consisting of one cartridge filter housing prior to the two (2) UV disinfection units.
- Clearwell/Storage Tank with high lift and backwash pumps.
- Residual Management System consisting of one backwash holding tank which discharges supernatant to the ditch and the remaining sludge is pumped via a connection at the building exterior.
- Standby Power consisting of generator with a 32 hour double wall sub-base fuel tank.
- There is also, one (1) programmable logic controller and associated SCADA system for control of plant operations, a chlorine residual analyzer, treated water turbidity analyzer, filtered water turbidity analyzer and Raw, Treated and Backwash flow meters.

## List all water treatment chemicals used over this reporting period

- Sodium Hypochlorite 12%

## Were any significant expenses incurred to?

- Install required equipment  
 Repair required equipment  
 Replace required equipment

## Describe:

Replaced battery for diesel generator  
 Replaced relay and fuses for PLC  
 Replaced dehumidifier unit

## Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|-----------|--------|-----------------|-------------------|------------------------|
|               |           |        |                 |                   |                        |

## O.Reg 170 SECTION 11 ANNUAL REPORT

Microbiological testing done under Schedule 10, 11 or 12 of Regulation 170/03 during this reporting Period

| Location          | Number of Samples | Range of E. Coli or Fecal Results (min #) - (max #) | Range of Total Coliform Results (min #) - (max #) | Number of HPC Samples | Range of HPC Results (min #) - (max #) |
|-------------------|-------------------|---|---|-----------------------|--|
| Raw - RWW1        | 55                | 0 - 0   | 0 - 0   |                       |  |
| Raw - RWW2        | 55                | 0 - 0   | 0 - 0   |                       |  |
| Raw - RWW3        | 55                | 0 - 0   | 0 - 0   |                       |  |
| Treated - TW      | 55                | 0 - 0   | 0 - 0   | 55                    | 0 - 1                                  |
| Distribution - DW | 104               | 0 - 0   | 0 - 0   | 52                    | 0 - 2                                  |

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

|                                       | Number of Grab Samples | Range of Results (#-#) |
|---------------------------------------|------------------------|------------------------|
| Filter Turbidity                      | 8760                   | 0.025-0.052            |
| Chlorine                              | 8760                   | 1.06-1.38              |
| Chlorine Residual Distribution System | 440                    | 0.54-1.44              |

*NOTE: For continuous monitors use 8760 as the number of samples.*

*NOTE: Record the unit of measure if it is not milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval or order.

| Date of order or C of A | Parameter                    | Date Sampled | Result               | C of A Limit | Unit of Measure |
|-------------------------|------------------------------|--------------|----------------------|--------------|-----------------|
| C of A 9049-6VURYU      | Suspended Solids (composite) | Quarterly    | Annual Average < 2.0 | 25           | mg/L            |

## O.Reg 170 SECTION 11 ANNUAL REPORT

### Summary of Inorganic parameters tested during this reporting period or most recent

| Parameter                | Sample Date | Sample Result | Exceedance |
|--------------------------|-------------|---------------|------------|
| Antimony: Sb (ug/L) - TW | 2014/01/27  | < 0.020       | No         |
| Arsenic: As (ug/L) - TW  | 2014/01/27  | 0.90          | No         |
| Barium: Ba (ug/L) - TW   | 2014/01/27  | 250.00        | No         |
| Boron: B (ug/L) - TW     | 2014/01/27  | 106.00        | No         |
| Cadmium: Cd (ug/L) - TW  | 2014/01/27  | 0.0030        | No         |
| Chromium: Cr (ug/L) - TW | 2014/01/27  | 0.60          | No         |
| Lead: Pb (ug/L) -        |             |               |            |
| Mercury: Hg (ug/L) - TW  | 2014/01/27  | < 0.010       | No         |
| Selenium: Se (ug/L) - TW | 2014/01/27  | < 1.00        | No         |
| Sodium: Na (mg/L) - TW   | 2011/01/10  | 13.50         | No         |
| Uranium: U (ug/L) - TW   | 2014/01/27  | 0.164         | No         |
| Fluoride: (mg/L) - TW    | 2011/01/17  | 1.35          | No         |
| Nitrite (mg/L) - TW      | 2014/01/20  | < 0.0030      | No         |
| Nitrite (mg/L) - TW      | 2014/04/14  | < 0.0030      | No         |
| Nitrite (mg/L) - TW      | 2014/07/14  | < 0.0030      | No         |
| Nitrite (mg/L) - TW      | 2014/10/20  | < 0.0030      | No         |
| Nitrate (mg/L) - TW      | 2014/01/20  | 0.016         | No         |
| Nitrate (mg/L) - TW      | 2014/04/14  | 0.017         | No         |
| Nitrate (mg/L) - TW      | 2014/07/14  | 0.083         | No         |
| Nitrate (mg/L) - TW      | 2014/10/20  | 0.018         | No         |

### Summary of Organic parameters sampled during this reporting period or most recent

| Parameter  | Sample Date | Result Value | Exceedance |
|--|-------------|--------------|------------|
| Alachlor (ug/L) - TW                             | 2014/01/27  | < 0.02       | No         |
| Aldicarb (ug/L) - TW                             | 2014/01/27  | < 0.01       | No         |
| Aldrin + Dieldrin (ug/L) - TW                    | 2014/01/27  | < 0.01       | No         |
| Atrazine + N-dealkylated metabolites (ug/L) - TW | 2014/01/27  | < 0.01       | No         |

## O.Reg 170 SECTION 11 ANNUAL REPORT

|  |            |         |    |
|--|------------|---------|----|
| Azinphos-methyl (ug/L) - TW                                    | 2014/01/27 | < 0.02  | No |
| Bendiocarb (ug/L) - TW   | 2014/01/27 | < 0.01  | No |
| Benzene (ug/L) - TW  | 2014/01/27 | < 0.32  | No |
| Benzo(a)pyrene (ug/L) -  | 2014/01/27 | < 0.004 | No |
| Bromoxynil (ug/L) - TW   | 2014/01/27 | < 0.33  | No |
| Carbaryl (ug/L) - TW   | 2014/01/27 | < 0.01  | No |
| Carbofuran (ug/L) - TW   | 2014/01/27 | < 0.01  | No |
| Carbon Tetrachloride (ug/L) - TW                               | 2014/01/27 | < 0.16  | No |
| Chlordane:Total (ug/L) - TW                                    | 2014/01/27 | < 0.01  | No |
| Chlorpyrifos (ug/L) - TW                                       | 2014/01/27 | < 0.02  | No |
| Cyanazine (ug/L) - TW  | 2014/01/27 | < 0.03  | No |
| Diazinon (ug/L) - TW   | 2014/01/27 | < 0.02  | No |
| Dicamba (ug/L) - TW  | 2014/01/27 | < 0.20  | No |
| 1,2-Dichlorobenzene (ug/L) - TW                                | 2014/01/27 | < 0.41  | No |
| 1,4-Dichlorobenzene (ug/L) - TW                                | 2014/01/27 | < 0.36  | No |
| Dichlorodiphenyltrichloroethane(DDT) + metabolites (ug/L) - TW | 2014/01/27 | < 0.01  | No |
| 1,2-Dichloroethane (ug/L) -                                    | 2014/01/27 | < 0.35  | No |
| 1,1-Dichloroethylene (ug/L) -                                  | 2014/01/27 | < 0.33  | No |
| Dichloromethane (ug/L) -                                       | 2014/01/27 | < 0.35  | No |
| 2,4-Dichlorophenol (ug/L) -                                    | 2014/01/27 | < 0.15  | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW            | 2014/01/27 | < 0.19  | No |
| Diclofop-methyl (ug/L) - TW                                    | 2014/01/27 | < 0.40  | No |
| Dimethoate (ug/L) - TW   | 2014/01/27 | < 0.03  | No |
| Dinoseb (ug/L) - TW  | 2014/01/27 | < 0.36  | No |
| Diquat (ug/L) -  | 2014/01/27 | < 1     | No |
| Diuron (ug/L) - TW   | 2014/01/27 | < 0.03  | No |
| Glyphosate (ug/L) -  | 2014/01/27 | < 1     | No |
| Heptachlor+Hepachlor Epoxide (ug/L) - TW                       | 2014/01/27 | < 0.01  | No |
| Lindane: (ug/L) - TW   | 2014/01/27 | < 0.01  | No |
| Malathion (ug/L) - TW  | 2014/01/27 | < 0.02  | No |
| Methoxychlor (ug/L) -  | 2014/01/27 | < 0.01  | No |

## O.Reg 170 SECTION 11 ANNUAL REPORT

|  |            |        |    |
|--|------------|--------|----|
| Metolachlor (ug/L) - TW                        | 2014/01/27 | < 0.01 | No |
| Metribuzin (ug/L) - TW                         | 2014/01/27 | < 0.02 | No |
| Monochlorobenzene (ug/L) -                     | 2014/01/27 | < 0.30 | No |
| Paraquat (ug/L) -                              | 2014/01/27 | < 1    | No |
| Parathion (ug/L) - TW                          | 2014/01/27 | < 0.02 | No |
| Pentachlorophenol (ug/L) - TW                  | 2014/01/27 | < 0.15 | No |
| Phorate (ug/L) - TW                            | 2014/01/27 | < 0.01 | No |
| Picloram (ug/L) - TW                           | 2014/01/27 | < 1.00 | No |
| Polychlorinated Bichenysl(PCB) (ug/L) -        | 2014/01/27 | < 0.04 | No |
| Prometryne (ug/L) - TW                         | 2014/01/27 | < 0.03 | No |
| Simazine (ug/L) - TW                           | 2014/01/27 | < 0.01 | No |
| THM (ug/L) – DW (Annual Average)               | 2014       | 24.25  | No |
| Temephos (ug/L) - TW                           | 2014/01/27 | < 0.01 | No |
| Terbufos (ug/L) - TW                           | 2014/01/27 | < 0.01 | No |
| Tetrachloroethylene (ug/L) -                   | 2014/01/27 | < 0.35 | No |
| 2,3,4,6-Tetrachlorophenol (ug/L) - TW          | 2014/01/27 | < 0.14 | No |
| Triallate (ug/L) - TW                          | 2014/01/27 | < 0.01 | No |
| Trichloroethylene (ug/L) -                     | 2014/01/27 | < 0.44 | No |
| 2,4,6-Trichlorophenol (ug/L) - TW              | 2014/01/27 | < 0.25 | No |
| 2,4,5-Trichlorophenoxy acetic acid (ug/L) - TW | 2014/01/27 | < 0.22 | No |
| Trifluralin (ug/L) - TW                        | 2014/01/27 | < 0.02 | No |
| Vinyl Chloride (ug/L) -                        | 2014/01/27 | < 0.17 | No |

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

| Parameter | Result Value | Unit of Measure | Date of Sample |
|-----------|--------------|-----------------|----------------|
| Fluoride  | 1.35         | mg/L            | 2011/01/17     |

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, small municipal non residential, large non municipal non residential)



# O.Reg 170 SECTION 11 ANNUAL REPORT

**Summary of lead testing under Schedule 15.1 during this reporting period**  
(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

| <b>Location Type</b> | <b>Number of Samples</b> | <b>Range of Lead Results (min#) – (max #)</b> | <b>Number of Exceedances</b> |
|----------------------|--------------------------|---|------------------------------|
| <b>Plumbing</b>      | <b>0</b>                 | <b>N/A</b>                                    | <b>N/A</b>                   |
| <b>Distribution</b>  | <b>4</b>                 | <b>0.07 – 0.38 µg/L</b>                       | <b>0</b>                     |

**\*\*\*System qualifies for Plumbing Exemption – the next distribution lead samples are scheduled to be taken in the summer sampling period of 2016.**

