AMABEL-SAUBLE DRINKING WATER SYSTEM
Physical Address: 628 D LINE, SOUTH BRUCE PENINSULA, ON N0H 2G0

INSPECTION REPORT

System Number:	220007917
Entity:	ONTARIO CLEAN WATER AGENCY THE CORPORATION OF THE TOWN OF SOUTH BRUCE PENINSULA
Inspection Start Date:	November 27, 2025
Site Inspection Date:	December 12, 2025
Inspection End Date:	January 05, 2026
Inspected By:	Matt Shannon
Badge #:	1021

(signature)

INTRODUCTION

Purpose

The primary focus of this inspection is to confirm compliance with Ministry of the Environment, Conservation and Parks (MECP) legislation as well as evaluating conformance with ministry drinking water policies and guidelines during the inspection period. The ministry utilizes a comprehensive, multi-barrier approach in the inspection of water systems that focuses on the source, treatment, and distribution components as well as management practices.

Scope

This drinking water system is subject to the legislative requirements of the Safe Drinking Water Act, 2002 (SDWA) and regulations made therein, including Ontario Regulation 170/03, "Drinking Water Systems" (O. Reg. 170/03). This inspection has been conducted pursuant to Section 81of the SDWA.

This inspection report does not suggest that all applicable legislation and regulations were evaluated. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

Facility Contacts and Dates

The inspection review period is from October 2, 2024 to December 12, 2025.

Systems/Components

The Amabel-Sauble Drinking Water System consists of three (3) wells, a treatment plant building housing chlorination equipment and facilities, packaged filtration treatment system for iron and manganese, cartridge filtration and UV disinfection, high lift pumps, process piping and valves, instrumentation and control systems, one underground storage reservoir and approximately 15.6 kilometers of distribution watermains.

Permissions/Approvals

MUNICIPAL DRINKING WATER LICENCE: Licence Number: 094-101 Issue Number: 5

DRINKING WATER WORKS PERMIT: Permit Number: 094-201 Issue Number: 6

PERMIT TO TAKE WATER (PTTW): #8444-AKMQCN Issued on May 5, 2017

NON-COMPLIANCE

This should not be construed as a confirmation of full compliance with all potential applicable legal requirements. These inspection findings are limited to the components and/or activities that were assessed, and the legislative framework(s) that were applied. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

If you have any questions related to this inspection, please contact the signed Provincial Officer.

RECOMMENDATIONS

This should not be construed as a confirmation of full conformance with all potential applicable BMPs. These inspection findings are limited to the components and/or activities that were assessed, and the legislative framework(s) that were applied. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

If you have any questions related to this inspection, please contact the signed Provincial Officer.

INSPECTION DETAILS

This section includes all questions that were assessed during the inspection.

Ministry Program: DRINKING WATER | **Regulated Activity:** DW Municipal Residential

Question ID	DWMR1007001	**Question Type**	Legislative
Legislative Requirement(s): SDWA | O. Reg. 170/03 | 1-2 | (1)1;			
Question: Was the owner maintaining the production well(s) in a manner sufficient to prevent entry into the well of surface water and other foreign materials?			
Compliance Response(s)/Corrective Action(s)/Observation(s): The owner was maintaining the production well(s) in a manner sufficient to prevent entry into the well of surface water and other foreign materials.			

Question ID	DWMR1009001	**Question Type**	Legislative
Legislative Requirement(s): SDWA | 31 | (1);			
Question: Were measures in place to protect the groundwater and/or GUDI source in accordance with the Municipal Drinking Water Licence and Drinking Water Works Permit?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Measures were in place to protect the groundwater and/or GUDI source.			

Question ID	DWMR1010001	**Question Type**	BMP
Legislative Requirement(s): Not Applicable			
Question: Were trends in source water quality monitored?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Trends in source water quality were monitored.			

Question ID	DWMR1014001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Was flow monitoring performed as required by the Municipal Drinking Water Licence or Drinking Water Works Permit?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Flow monitoring was performed as required.

Question ID	DWMR1015001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Were flow measuring devices calibrated or verified in accordance with the requirements of the Municipal Drinking Water Licence?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Flow measuring devices were calibrated or verified as required.

Question ID	DWMR1016001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Was the owner in compliance with the conditions associated with maximum flow rate or the rated/operational capacity in the Municipal Drinking Water Licence?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner was in compliance with the conditions associated with maximum flow rate and/or the rated/operational capacity conditions.

Question ID	DWMR1017001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Were appropriate records of flows and any capacity exceedances made in accordance with the Municipal Drinking Water Licence?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Appropriate records of flows and any capacity exceedances were made as required.

Question ID	DWMR1013001	Question Type	Legislative

Legislative Requirement(s):
OWRA | 34 | (3);

Question:
Was the owner in compliance with all conditions of the Permit To Take Water?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner was in compliance with all conditions of the Permit To Take Water.

Question ID	DWMR1018001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Did the owner ensure that equipment was installed in accordance with Schedule A and Schedule C of the Drinking Water Works Permit?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner ensured that equipment was installed as required.

Question ID	DWMR1028001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Were up-to-date plans for the drinking water system made available in such a manner that they could be readily viewed by all persons responsible for all or part of the operation of the drinking water system, in accordance with the Drinking Water Works Permit and Municipal Drinking Water Licence?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Plans for the drinking water system were kept up-to-date and made available as required.

Question ID	DWMR1025001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Were all parts of the drinking water system that came in contact with drinking water disinfected in accordance with a procedure listed in Schedule B of the Drinking Water Works Permit?

Compliance Response(s)/Corrective Action(s)/Observation(s):
All parts of the drinking water system were disinfected as required.

Question ID	DWMR1023001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 1-2 | (2);

Question:
Did records indicate that the treatment equipment was operated in a manner that achieved the design capabilities prescribed by O. Reg. 170/03, Drinking Water Works Permit and/or Municipal Drinking Water Licence at all times that water was being supplied to consumers?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Records indicated that the treatment equipment was operated in a manner that achieved the design capabilities prescribed.

Treatment for a GUDI water source is required to achieve 2-log removal or inactivation of Cryptosporidium oocysts, a 3-log removal or inactivation of Giardia cysts and a 4-log removal or inactivation of viruses.

These requirements are met by UV disinfection followed by chlorination using sodium hypochlorite for both primary and secondary disinfection purposes.

According to Schedule E of the MDWL, the UV disinfection process is credited with 3 log Giardia cyst removal, 2 log Cryptosporidium oocyst removal and 2 log virus removal credits, with the UV disinfection process being fully operational and the applicable log removal/inactivation credit assignment criteria being met. The Chlorination disinfection process is credited with 2+ Virus log removal/inactivation credits, if the chlorination process meets MDWL Schedule E chlorination treatment criteria.

Records reviewed indicate that the Amabel-Sauble Water Treatment Plant was operated to achieve the necessary CT requirements and performance criteria for primary disinfection purposes during the inspection time period.

Question ID	DWMR1026001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 1-6 | (2);

Question:
If primary disinfection equipment did not use chlorination or chloramination, was the equipment equipped with alarms or shut-off mechanisms that satisfy the standards described in Schedule 1-6 of O. Reg. 170/03?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Primary disinfection equipment was equipped with alarms or shutoff mechanisms that satisfied the standards.

Question ID	DWMR1027001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Did the owner have evidence indicating that chemicals and materials that came in contact with water within the drinking water system met all applicable AWWA and ANSI standards in accordance with the Municipal Drinking Water Licence and Drinking Water Works Permit?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner had evidence indicating that chemicals and materials that came in contact with water within the drinking water system met the applicable standards.

Question ID	DWMR1024001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 1-2 | (2);

Question:
Did records confirm that the water treatment equipment which provides chlorination or chloramination for secondary disinfection was operated as required?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Records confirmed that the water treatment equipment which provides chlorination or chloramination for secondary disinfection was operated as required.

Question ID	DWMR1033001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 7-2 | (3); SDWA | O. Reg. 170/03 | 7-2 | (4);

Question:
Was secondary disinfectant residual tested as required for the large municipal residential distribution system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Secondary disinfectant residual was tested as required.

Question ID	DWMR1049001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
Did records confirm that disinfectant residuals were routinely checked at the extremities and dead ends of the distribution system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Records confirmed that disinfectant residuals were routinely checked at the extremities and dead ends of the distribution system.

Question ID	DWMR1036001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-7 | (1);

Question:
Where continuous monitoring equipment was not used for chlorine residual analysis, were samples tested using an acceptable portable device?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Samples for chlorine residual analysis were tested using an acceptable portable device.

Question ID	DWMR1030001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 7-2 | (1); SDWA | O. Reg. 170/03 | 7-2 | (2);

Question:
Was primary disinfection chlorine monitoring being conducted at a location approved by Municipal Drinking Water Licence and/or Drinking Water Works Permit or at/near a location where the intended CT had just been achieved?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Primary disinfection chlorine monitoring was conducted as required.

Question ID	DWMR1031001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
Were operators aware of the operational criteria necessary to achieve primary disinfection within the drinking water system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Operators were aware of the operational criteria necessary to achieve primary disinfection within the drinking water system.

Question ID	DWMR1035001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-5 | (1)1-4;

Question:
Were operators examining continuous monitoring test results and did they examine the results within 72 hours of the test?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Operators were examining continuous monitoring test results as required.

Question ID	DWMR1038001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-5 | (1)1-4;

Question:
Was continuous monitoring equipment that was being utilized to fulfill O. Reg. 170/03 requirements performing tests for the parameters with at least the minimum frequency and recording data with the prescribed format?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Continuous monitoring equipment that was being utilized to fulfill O. Reg. 170/03 requirements was performing tests for the parameters with at least the minimum frequency and recording data with the prescribed format.

Question ID	DWMR1037001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-5 | (1)5-10; SDWA | O. Reg. 170/03 | 6-5 | (1.1);

Question:
Were all continuous monitoring equipment utilized for sampling and testing required by O. Reg. 170/03, or Municipal Drinking Water Licence or Drinking Water Works Permit or order, equipped with alarms or shut-off mechanisms that satisfied the standards described in Schedule 6?

Compliance Response(s)/Corrective Action(s)/Observation(s):
All required continuous monitoring equipment utilized for sampling and testing were equipped with alarms or shut-off mechanisms that satisfied the standards

Question ID	DWMR1040001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-5 | (1)1-4; SDWA | O. Reg. 170/03 | 6-5 | (1)5-10;

Question:
Were all continuous analysers calibrated, maintained, and operated, in accordance with the manufacturer's instructions or the regulation?

Compliance Response(s)/Corrective Action(s)/Observation(s):
All continuous analysers were calibrated, maintained, and operated as required.

Question ID	DWMR1108001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-5 | (1)5-10; SDWA | O. Reg. 170/03 | 6-5 | (1.1);

Question:
Where continuous monitoring equipment used for the monitoring of free chlorine residual, total chlorine residual, combined chlorine residual or turbidity, required by O. Reg. 170/03, Municipal Drinking Water Licence, Drinking Water Works Permit, or order triggered an alarm or an automatic shut-off, did a qualified person respond as required and take appropriate actions?

Compliance Response(s)/Corrective Action(s)/Observation(s):
A qualified person responded as required and took appropriate actions.

Question ID	DWMR1039001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 1-6 | (3);

Question:
If primary disinfection equipment that does not use chlorination or chloramination was used, did the owner and operating authority ensure the equipment had a recording device that continuously recorded the performance of the disinfection equipment?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner and operating authority ensured that the primary disinfection equipment had a recording device that continuously recorded the performance of the disinfection equipment.

Question ID	DWMR1109001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 1-6 | (1); SDWA | O. Reg. 170/03 | 1-6 | (2);

Question:
If the system used equipment for primary disinfection other than chlorination or chloramination and the equipment malfunctioned, lost power, or ceased to provide the appropriate level of disinfection, causing an alarm or an automatic shut-off, did a certified operator respond as required and take appropriate actions?

Compliance Response(s)/Corrective Action(s)/Observation(s):
A certified operator responded as required and took appropriate actions.

Question ID	DWMR1042001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
If UV disinfection was used, were duty sensors and reference UV sensors checked and calibrated as per the requirements of Schedule E of the Municipal Drinking Water Licence or at a frequency as otherwise recommended by the UV equipment manufacturer?

Compliance Response(s)/Corrective Action(s)/Observation(s):
All UV sensors were checked and calibrated as required.

Question ID	DWMR1099001	Question Type	Information

Legislative Requirement(s):
Not Applicable

Question:
Do records show that water provided by the drinking water system met the Ontario Drinking Water Quality Standards?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Records showed that all water sample results met the Ontario Drinking Water Quality Standards.

Question ID	DWMR1079001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 10-4 | (1); SDWA | O. Reg. 170/03 | 10-4 | (2); SDWA | O. Reg. 170/03 | 10-4 | (3);

Question:
Were raw water microbiological sampling requirements prescribed by Schedule 10-4 of O. Reg. 170/03 for large municipal residential systems met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Raw water microbiological sampling requirements were met.

Question ID	DWMR1083001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 10-3;

Question:
Were treated microbiological sampling requirements prescribed by Schedule 10-3 of O. Reg. 170/03 for large municipal residential systems met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Treated microbiological sampling requirements were met.

Question ID	DWMR1081001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 10-2 | (1); SDWA | O. Reg. 170/03 | 10-2 | (2); SDWA | O. Reg. 170/03 | 10-2 | (3);

Question:
Were distribution microbiological sampling requirements prescribed by Schedule 10-2 of O. Reg. 170/03 for large municipal residential systems met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Distribution microbiological sampling requirements were met.

Question ID	DWMR1096001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-3 | (1);

Question:
Did records confirm that chlorine residual tests were conducted at the same time and location as microbiological samples?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Records confirmed that chlorine residual tests were conducted as required.

Question ID	DWMR1084001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13-2;

Question:
Were inorganic parameter sampling requirements prescribed by Schedule 13-2 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Inorganic parameter sampling requirements were met.

Inorganic parameters were last sampled in January 2025.

Question ID	DWMR1085001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13-4 | (1); SDWA | O. Reg. 170/03 | 13-4 | (2); SDWA | O. Reg. 170/03 | 13-4 | (3);

Question:
Were organic parameter sampling requirements prescribed by Schedule 13-4 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Organic parameter sampling requirements were met.

Organic parameters were last sampled in January 2025.

Question ID	DWMR1086001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13-6.1 | (1); SDWA | O. Reg. 170/03 | 13-6.1 | (2); SDWA | O. Reg. 170/03 | 13-6.1 | (3); SDWA | O. Reg. 170/03 | 13-6.1 | (4); SDWA | O. Reg. 170/03 | 13-6.1 | (5); SDWA | O. Reg. 170/03 | 13-6.1 | (6);

Question:
Were haloacetic acid sampling requirements prescribed by Schedule 13-6 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Haloacetic acid sampling requirements were met.

The current running annual average concentration of HAA is 6.1 ug/L. The Ontario Drinking Water Quality Standard is a running average of 80 ug/L.

Question ID	DWMR1087001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13-6 | (1); SDWA | O. Reg. 170/03 | 13-6 | (2); SDWA | O. Reg. 170/03 | 13-6 | (3); SDWA | O. Reg. 170/03 | 13-6 | (4); SDWA | O. Reg. 170/03 | 13-6 | (5); SDWA | O. Reg. 170/03 | 13-6 | (6);

Question:
Were trihalomethane sampling requirements prescribed by Schedule 13-6 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Trihalomethane sampling requirements were met.

The current running annual average concentration of THM is 32 ug/L. The Ontario Drinking Water Quality Standard is a running average of 100 ug/L.

Question ID	DWMR1088001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13-7;

Question:
Were nitrate/nitrite sampling requirements prescribed by Schedule 13-7 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Nitrate/nitrite sampling requirements were met.

Question ID	DWMR1089001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13-8;

Question:
Were sodium sampling requirements prescribed by Schedule 13-8 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Sodium sampling requirements were met.

The most recent sodium sample date was in January 2025 with a result of 14.3 mg/L, below the O.Reg. 170/03 reporting limit of 20.0 mg/L.

Question ID	DWMR1090001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13-9;

Question:
Where fluoridation is not practiced, were fluoride sampling requirements prescribed by Schedule 13-9 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Fluoride sampling requirements were met.

The most recent fluoride sample was collected in January 2025 with a result of 1.42 mg/L, below the ODWQS of 1.5 mg/L.

Question ID	DWMR1092001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-2;

Question:
Were water samples taken at the prescribed location?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Water samples were taken at the prescribed location.

Question ID	DWMR1095001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 15.1-10; SDWA | O. Reg. 170/03 | 15.1-4 | (1); SDWA | O. Reg. 170/03 | 15.1-5 | (1); SDWA | O. Reg. 170/03 | 15.1-5 | (10); SDWA | O. Reg. 170/03 | 15.1-5 | (11); SDWA | O. Reg. 170/03 | 15.1-5 | (2); SDWA | O. Reg. 170/03 | 15.1-5 | (3); SDWA | O. Reg. 170/03 | 15.1-5 | (4); SDWA | O. Reg. 170/03 | 15.1-5 | (5); SDWA | O. Reg. 170/03 | 15.1-5 | (6); SDWA | O. Reg. 170/03 | 15.1-5 | (7); SDWA | O. Reg. 170/03 | 15.1-5 | (8); SDWA | O. Reg. 170/03 | 15.1-5 | (9); SDWA | O. Reg. 170/03 | 15.1-7 | (1); SDWA | O. Reg. 170/03 | 15.1-7 | (2); SDWA | O. Reg. 170/03 | 15.1-7 | (3); SDWA | O. Reg. 170/03 | 15.1-7 | (4); SDWA | O. Reg. 170/03 | 15.1-9 | (1); SDWA | O. Reg. 170/03 | 15.1-9 | (2); SDWA | O. Reg. 170/03 | 15.1-9 | (3); SDWA | O. Reg. 170/03 | 15.1-9 | (4); SDWA | O. Reg. 170/03 | 15.1-9 | (5); SDWA | O. Reg. 170/03 | 15.1-9 | (6); SDWA | O. Reg. 170/03 | 15.1-9 | (7); SDWA | O. Reg. 170/03 | 15.1-9 | (8); SDWA | O. Reg. 170/03 | 15.1-9 | (9);

Question:
Were lead sampling requirements prescribed by Schedule 15.1 of O. Reg. 170/03 met?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Lead sampling requirements were met.

Question ID	DWMR1110001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 11 | (6);

Question:
Was the annual report prepared by February 28th of the following year and did it contain the required information?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The annual report requirements were met.

Question ID	DWMR1111001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 22-2 | (1); SDWA | O. Reg. 170/03 | 22-2 | (2); SDWA | O. Reg. 170/03 | 22-2 | (3); SDWA | O. Reg. 170/03 | 22-2 | (4);

Question:
Did the summary report contain the required information and was it completed and distributed as required?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The summary report requirements were met.

Question ID	DWMR1113001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 10.1 | (3);

Question:
Were changes to the system registration information provided to the ministry within ten (10) days of the change?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Changes to the system registration information were provided as required.

Question ID	DWMR1098001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 13 | (1); SDWA | O. Reg. 170/03 | 13 | (2); SDWA | O. Reg. 170/03 | 13 | (3);

Question:
Were the required records kept for the periods prescribed by section 13 of O. Reg. 170/03?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The required records were kept for the prescribed periods.

Question ID	DWMR1045001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Did the owner update the document describing the distribution components within 12 months of completion of alterations to the system in accordance with the Drinking Water Works Permit?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner had up-to-date documents describing the distribution components.

Question ID	DWMR1046001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
Was there a backflow prevention program, policy and/or bylaw in place that addressed cross connections and connections to high hazard facilities?

Compliance Response(s)/Corrective Action(s)/Observation(s):
There was a backflow prevention program, policy and/or bylaw in place.

Question ID	DWMR1053001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
Was the owner able to maintain proper pressures in the distribution system and was pressure monitored to alert the operator of conditions of loss of pressure below the value under which

the system was designed to operate?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner was able to maintain proper pressures in the distribution system and pressure was monitored to alert the operator of conditions which may lead to loss of pressure below the value under which the system is designed to operate.

Question ID	DWMR1048001	**Question Type**	BMP

Legislative Requirement(s):
Not Applicable

Question:
Had the owner implemented a program for the flushing of watermains as per industry standards?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner had implemented a program for the flushing of watermains.

Question ID	DWMR1050001	**Question Type**	BMP

Legislative Requirement(s):
Not Applicable

Question:
Was there a program in place for inspecting and exercising valves?

Compliance Response(s)/Corrective Action(s)/Observation(s):
There was a program in place for inspecting and exercising valves.

Question ID	DWMR1051000	**Question Type**	BMP

Legislative Requirement(s):
Not Applicable

Question:
Is there a program in place for inspecting and operating hydrants?

Compliance Response(s)/Corrective Action(s)/Observation(s):
There was a program in place for inspecting and operating hydrants.

Question ID	DWMR1052001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
Was there a bylaw or policy in place limiting access to hydrants?

Compliance Response(s)/Corrective Action(s)/Observation(s):
There was a bylaw or policy in place limiting access to hydrants.

Question ID	DWMR1058001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 128/04 | 28;

Question:
Did operators and maintenance personnel have ready access to operations and maintenance manuals?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Operators and maintenance personnel had ready access to operations and maintenance manuals.

Question ID	DWMR1059001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 128/04 | 28;

Question:
Did the operations and maintenance manuals contain plans, drawings, and process descriptions sufficient for the safe and efficient operation of the system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The operations and maintenance manuals contained plans, drawings, and process descriptions sufficient for the safe and efficient operation of the system.

Question ID	DWMR1060001	Question Type	Legislative

Legislative Requirement(s):
SDWA | 31 | (1);

Question:
Did the operations and maintenance manual(s) meet the requirements of the Municipal Drinking Water Licence?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The operations and maintenance manual(s) met the requirements of the Municipal Drinking Water Licence.

Question ID	DWMR1064001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 128/04 | 26 | (2);

Question:
Did an operator-in-charge ensure that records were maintained of all adjustments to the processes within their responsibility?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The operator-in-charge ensured that records were maintained of all adjustments to the processes within their responsibility.

Question ID	DWMR1062001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 7-5;

Question:
Did records or other record keeping mechanisms confirm that operational testing not performed by continuous monitoring equipment was done by a certified operator, water quality analyst, or person who met the requirements of Schedule 7-5 of O. Reg. 170/03?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Records or other record keeping mechanisms confirmed that operational testing not performed by continuous monitoring equipment was done by a certified operator, water quality analyst, or person who met the requirements of Schedule 7-5 of O. Reg. 170/03.

Question ID	DWMR1063001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 170/03 | 6-10 | (1);

Question:
For every required operational test and sample, was a record made of the date, time, location, results, and name of the person conducting the test?

Compliance Response(s)/Corrective Action(s)/Observation(s):
For every required operational test and sample, a record was made as required.

Question ID	DWMR1061001	Question Type	Legislative
Legislative Requirement(s): SDWA | O. Reg. 128/04 | 27 | (1); SDWA | O. Reg. 128/04 | 27 | (2); SDWA | O. Reg. 128/04 | 27 | (3); SDWA | O. Reg. 128/04 | 27 | (4); SDWA | O. Reg. 128/04 | 27 | (5); SDWA | O. Reg. 128/04 | 27 | (6); SDWA | O. Reg. 128/04 | 27 | (7);			
Question: Were logbooks properly maintained and did they contain the required information?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Logbooks were properly maintained and contained the required information.			

Question ID	DWMR1065001	Question Type	Legislative
Legislative Requirement(s): SDWA | O. Reg. 128/04 | 27 | (6);			
Question: Were logs and other record keeping mechanisms available for at least five (5) years?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Logs or other record keeping mechanisms were available for at least five (5) years.			

Question ID	DWMR1066001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Was spill containment provided for process chemicals and standby power generator fuel?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Spill containment was provided for process chemicals and/or standby power generator fuel.			

Question ID	DWMR1067001	Question Type	BMP
Legislative Requirement(s): Not Applicable			
Question: Were equipment and materials in place for the clean up of spills?			

Compliance Response(s)/Corrective Action(s)/Observation(s):
Equipment and materials were in place for the clean up of spills.

Question ID	DWMR1068001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
If available, were standby power generators tested under normal load conditions?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Standby power generators were tested under normal load conditions.

Question ID	DWMR1071001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
Did the owner provide security measures to protect components of the drinking water system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner provided security measures to protect components of the drinking water system.

Question ID	DWMR1072001	Question Type	BMP

Legislative Requirement(s):
Not Applicable

Question:
Had the owner and/or operating authority undertaken efforts to promote water conservation and reduce water losses in the drinking water system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
The owner and/or operating authority undertook efforts to promote water conservation and reduce water losses in their system.

Question ID	DWMR1073001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 128/04 | 23 | (1);

Question:
Was an overall responsible operator designated for all subsystems which comprise the drinking water system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
An overall responsible operator was designated for all subsystem.

Question ID	DWMR1078001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 128/04 | 23 | (1); SDWA | O. Reg. 128/04 | 23 | (2); SDWA | O. Reg. 128/04 | 23 | (4); SDWA | O. Reg. 128/04 | 23 | (6); SDWA | O. Reg. 128/04 | 23 | (7);

Question:
When the overall responsible operator was unable to act, was a properly certified operator designated to act in their place?

Compliance Response(s)/Corrective Action(s)/Observation(s):
A properly certified operator was designated to act in place of the overall responsible operator.

Question ID	DWMR1074001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 128/04 | 25 | (1);

Question:
Were operators-in-charge designated for all subsystems which comprise the drinking water system?

Compliance Response(s)/Corrective Action(s)/Observation(s):
Operators-in-charge were designated for all subsystems.

Question ID	DWMR1075001	Question Type	Legislative

Legislative Requirement(s):
SDWA | O. Reg. 128/04 | 22;

Question:
Were all operators certified as required?

Compliance Response(s)/Corrective Action(s)/Observation(s):
All operators were certified as required.

Question ID	DWMR1076001	Question Type	Legislative
Legislative Requirement(s): SDWA | O. Reg. 170/03 | 1-2 | (2);			
Question: Were adjustments to the treatment equipment only made by certified operators?			
Compliance Response(s)/Corrective Action(s)/Observation(s): Adjustments to the treatment equipment were only made by certified operators.			

DWS Name: AMABEL-SAUBLE DRINKING WATER SYSTEM
DWS Number: 220007917
DWS Owner: THE CORPORATION OF THE TOWN OF SOUTH BRUCE PENINSULA
Municipal Location: SOUTH BRUCE PENINSULA

Regulation: O.REG. 170/03
DWS Category: DW Municipal Residential
Type of Inspection: Detailed
Compliance Assessment Start Date: Nov-27-2025
Ministry Office: Owen Sound District Office

Maximum Risk Rating: 631

Inspection Module	Non Compliance Risk (X out of Y)
Capacity Assessment	0/42
Certification and Training	0/49
Distribution System	0/4
Logbooks	0/30
Operations Manuals	0/42
Reporting & Corrective Actions	0/54
Source	0/26
Treatment Processes	0/248
Water Quality Monitoring	0/136
Overall - Calculated	**0/631**

Inspection Risk Rating: **0.00%**

Final Inspection Rating: **100.00%**

DWS Name:	AMABEL-SAUBLE DRINKING WATER SYSTEM
DWS Number:	220007917
DWS Owner Name:	THE CORPORATION OF THE TOWN OF SOUTH BRUCE PENINSULA
Municipal Location:	SOUTH BRUCE PENINSULA
Regulation:	O.REG. 170/03
DWS Category:	DW Municipal Residential
Type of Inspection:	Detailed
Compliance Assessment Start Date:	Nov-27-2025
Ministry Office:	Owen Sound District Office

All legislative requirements were met. No detailed rating scores.

Maximum Question Rating: 631

Inspection Risk Rating:	**0.00%**

FINAL INSPECTION RATING:	**100.00%**